

Zertifikat *Certificate*

Zertifikatsnummer Certificate No.:

R 50712370 0001

Berichtsnummer Report No.:

CN254K5U 001

Genehmigungsinhaber License Holder:

Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area,
Liushi Town, Yueqing City,
325604 Zhejiang
P.R. China

Fertigungsstätte Manufacturing Site:

Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area,
Liushi Town, Yueqing City,
325604 Zhejiang
P.R. China

Prüfzeichen Test Mark:

Geprüft nach Tested according to:

EN IEC 61558-1:2019
EN IEC 61558-2-2:2025

Geräteidentifikation
Product Identification

Produkt: Transformator
Product: (Toroidal Transformer)

Modell: Modelle sind auf nächste(r) Seite(n) gelistet
Type: Type designation(s) are listed on the next page(s)

Technische Daten: Technische Daten auf nächste(r) Seite(n) gelistet
Technical Data: Technical Data is listed on the next page(s)

Gültig ab: 2026-02-14

Valid from:

Zertifizierungsstelle:

Certification body:

Ausstellungsdatum: 2026-02-14

Date of issue:

Yongming Yang

Yongming Yang



Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

<http://www.tuv.com/safety> E-mail: markcheck@tuv.com

Fax: +49 221 806-3935

www.tuv.com

 **TÜVRheinland®**
Precisely Right.

Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*

R 50712370 0001

Berichtsnummer *Report No.:*

CN254K5U 001

Produkt *Product:* Transformator
(Toroidal Transformer)

Modell *Type:* **Bezeichnung** *Designation:*
1)TGBOD-300, 2)TGBOD-200

Rated Input Ratings	: 1)220V/1.36A/299.2VA; 50/60Hz 2)220V/ 0.9A/ 198VA; 50/60Hz
Rated Output Ratings	: 1) 42V/ 7.1A/ 298.2VA 2) 36V/ 5.5A/ 198VA
Rated Ambient Temperature	: 25°C
Insulation Classification	: Class B
Degree of Protection	: IP00
Method of Installation	: Open
Short-circuit Characteristics:	Non-inherently short-circuit proof

ANLAGE (Appendix): 1

